



FINAL REPORT OF ANALYSIS

Todd Environmental Assoc. Inc.
PO Box 296
Fallston, MD 21047

Report Date: 10/02/2020
Report Number: 201002130030

LAB#- E064673-01 SAMPLE ID- 2730 Register Farm Rd WELL #
LOCATION- Powder Room SAMPLER- 3667TT
DATE SAMPLED- 09/29/2020 TIME SAMPLED- 13:30 Residual Chlorine- Non detect
DATE RECEIVED- 09/29/2020 TIME RECEIVED- 16:25
DELIVERED BY- Todd Thropp RECEIVED BY- Ginny Shelley
COMMENTS-

ANALYSIS	METHOD	ANALYSIS DATE/TIME	BY	RESULT	DATA FLAG
Microbiology by Enviro-Chem					
E. Coli	SM 9223B	09/29/20 17:00	VPS	Absent	PASS
Total Coliform	SM 9223B	09/29/20 17:00	VPS	Absent	PASS

Based on coliform bacteriological standards, at the time of sampling this water was **SAFE** for drinking water purposes.

Stephen Shelley
Laboratory Director

Certifications

State of Maryland Laboratory

#192